

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202

This form must be completed and filed with the department and owner within 60 days upon completion of the well.

Email address: water.well@license.state.tx.us

WELL REPORT

A. WELL IDENTIFICATION AND LOCATION DATA

1) OWNER

Name HERRY ABERNETHY	Address 343 SPARKS HWY	City EVANT	State TX.	Zip 76572
--------------------------------	----------------------------------	----------------------	---------------------	---------------------

2) WELL LOCATION


County LAMPASAS	Physical Address HWY 281	City EVANT	State TX	Zip 76572
---------------------------	------------------------------------	----------------------	--------------------	---------------------

3) Type of Work

New Well Reconditioning
 Replacement Deepening

Lat. _____ **Long.** _____ **Grid #** **41-39-6**

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
 Rig Supply If Public Supply well, were plans submitted? Yes No



6) Drilling Date

Started **10/17/05**
Completed **10/17/05**

Diameter of Hole

Dia. (in)	From (ft)	To (ft)
8 1/2	0	10
6 1/2	10	150

7) Drilling Method (check)

Air Rotary Mud Rotary Driven
 Air Hammer Cable Tool Bored
 Jetted
 Other **WELL**

From (ft) To (ft) Description and color of formation material

0-1	SOIL
1-18	CALEACHE
18-32	GRAY SHALE
32-48	BROWN SAND
48-150	GRAY SHALE
WATER AT 44'	

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____

If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
4 1/2 N	PLASTIC	7-74	SDM		
4 1/2 N	SCREEN	74-114	SDM		
4 1/2 N	PLASTIC	114-144	SDM		
	1030				

9) Cementing Data

Cementing from _____ ft. to **24** ft. # of sacks used **1 1/2**
ft. to _____ ft. # of sacks used _____
Method Used **SAND & CEMENT**
Cementing By **DALE FAUGHT JR.**
Distance to septic system field or other concentrated contamination _____ ft.
Method of verification of above distance **NONE**

13) Plugged Well plugged within 48 hours

Casing left in well: _____ Cement/Bentonite placed in well: _____

From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

10) Surface Completion

Specified Surface Slab Installed
 Specified Surface Sleeve Installed **7 1/2" x 7 1/2"**
 Pitless Adapter Used
 Approved Alternative Procedure Used

14) Type Pump

Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet etc., _____ ft.

15) Water Test

Typetest Pump Bailer Jetted Estimated
Yield: **4** gpm with _____ ft. drawdown after _____ hrs.

16) Water Quality

Did you knowingly penetrate a strata which contain undesirable constituents.
 YES NO If yes, did you submit a REPORT OF UNDESIRABLE WATER
Type of water _____ Depth of Strata _____
Was a chemical analysis made Yes No

11) Water Level

Static level **32** ft. below Date **10/17/05**
Artesian Flow _____ gpm. Date **1/1**

12) Packers

Type	Depth
1 RUBBER	24

Company or individual's Name (type or print) DALE FAUGHT JR.	Lic. No. 7410AKL
Address 191 CR 1463	City LAMPASAS
State TX	Zip 76570
Signature Dale Faught Jr.	Signature 1/1
Licensed Driller/Pump Installer	Date 10/17/05
Apprentice	Date