

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

Email address: water.well@license.state.tx.us

WELL REPORT

IDENTIFICATION AND LOCATION DATA

1) OWNER

Name <i>Loren Lackey</i>	Address <i>3801 Greenbriar Rd</i>	City <i>Gatesville</i>	State <i>TX</i>	Zip <i>76528</i>
-----------------------------	--------------------------------------	---------------------------	--------------------	---------------------

2) WELL

County <i>Coryell 50</i>	Physical Address <i>Same as above</i>	City	State	Zip
-----------------------------	------------------------------------------	------	-------	-----

3) Type of Work

New Well Reconditioning
 Replacement Deepening

Lat. *31°26.081* Long. *97°32.274* Grid # *40-36-4*

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
 Rig Supply If Public Supply well, were plans submitted? Yes No

6) Drilling Date

Started *10/31/02*
Completed *11/1/02*

Diameter of Hole		
Dia. (in)	From (ft)	To (ft)
<i>11</i>	<i>0</i>	<i>17</i>
<i>6 3/4</i>	<i>17</i>	<i>900</i>

7) Drilling Method (check) Driven

Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

From (ft) To (ft) Description and color of formation material

<i>0-12</i>	<i>overburden</i>
<i>12-397</i>	<i>gray lime + shale</i>
<i>397-440</i>	<i>green shale, gray shale, tan lime</i>
<i>440-547</i>	<i>gray lime + shale</i>
<i>547-660</i>	<i>gray sandstone + tan lime</i>
<i>660-702</i>	<i>sand + gravel w/ layers green shale</i>
<i>702-780</i>	<i>red bed</i>
<i>780-843</i>	<i>sand w/ layers red shale + tan lime</i>
<i>843-890</i>	<i>sand + gravel</i>
<i>890-900</i>	<i>yellow + brown shale</i>

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____
If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
<i>4 1/2</i>	<i>New</i>	<i>Plastic - solid</i>	<i>12</i>	<i>780</i>	
<i>4 1/2</i>	<i>New</i>	<i>Plastic - slotted</i>	<i>780</i>	<i>900</i>	<i>Old</i>

9) Cementing Data

Cementing from *0* ft. to *35* ft. # of sacks used *46* ^{sacks} *3* ^{bags} *cement*
ft. to _____ ft. # of sacks used _____
Method Used *gravity feed*
Cementing By *Tommy Lovelace*
Distance to septic system field or other concentrated contamination *700'*
Method of verification of above distance *measured*

13) Plugged Well plugged within 48 hours

Casing left in well: <i>Cement/Bentonite placed in well.</i>				
From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

14) Type Pump

Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet etc. *647* ft.

15) Water Test

Type test Pump Bailor Jetted Estimated
Yield: *200* gpm with _____ ft. drawdown after _____ hrs.

16) Water Quality

Did you knowingly penetrate a strata which contain undesirable constituents.
 YES NO If yes, did you submit a REPORT OF UNDESIRABLE WATER
Type of water _____ Depth of Strata _____
Was a chemical analysis made Yes No

10) Surface Completion

Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

11) Water Level

Static level *454* ft. below Date *NOV 18 2004*
Artesian Flow _____ gpm. Date _____

12) Packers

	Type	Depth
<i>1</i>	<i>ICEO - Rubber</i>	<i>780'</i>
<i>1</i>	<i>Rubber</i>	<i>500'</i>
<i>1</i>	<i>Rubber</i>	<i>35'</i>

Company or individual's Name (type or print) <i>Tom Lovelace Water Well Serv</i>	Lic. No. <i>4920PKLW</i>
Address <i>4997 Elm Grove Rd</i>	City <i>Bellton</i> State <i>TX</i> Zip <i>76513</i>
Signature <i>Tommy Lovelace</i> Date <i>11/28/02</i>	Signature _____