

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
 P.O. Box 12157 Austin, Texas 78711 (512) 463-7880 FAX (512) 463-8616
 Toll free (800) 803-9202
 Email address: water.well@license.state.tx.us
WELL REPORT

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

1) OWNER

A. WELL IDENTIFICATION AND LOCATION DATA

Name JERRY	Address SMITH	City COPPERAS COVE	State TX	Zip 76522
----------------------	-------------------------	------------------------------	--------------------	---------------------

2) WELL LOCATION

County CORYELL	Physical Address HWY 116	City PIDCOKE	State TX	Zip 76522
--------------------------	------------------------------------	------------------------	--------------------	---------------------

3) Type of Work

New Well Deepening
 Reconditioning

Lat. **31** | **17** | **28N** Long. **097** | **53** | **12W** Grid # **40-41-9**

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
 If Public Supply well, were plans submitted to the TNRCC? Yes No

5) N↑

6) Drilling Date

Started **11/10/2000**

Completed **11/10/2000**

Diameter of Hole		
Dia. (in)	From (ft)	To (ft)
8	0	29
6 1/2	29	342

7) Drilling Method (check) Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

From (ft)	To (ft)	Description and color of formation material
0	29	CLAY & GRAVEL
29	220	GRAY SHALE
220	268	TAN ROCK
268	270	GRAY CLAY
270	296	RED CLAY
296	300	TAN ROCK
300	342	RED CLAY

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____
 If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data					
Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
5	N	PVC	0	222	SDR 21
5	N	PERFORATED	222	262	SDR 21
5	N	PERFORATED	262	342	SDR 17

9) Cementing Data
 Cementing from **0** **35** ft. # of sacks used _____
 _____ ft. to _____ ft. # of sacks used _____
 Method Used **GROUT**
 Cementing By **SMART DRILLING & SUPPLY CO. INC.**
 Distance to septic system field or other concentrated contamination **N/A** ft.
 Method of verification of above distance _____

13) Plugged

Well plugged within 48 hours

Casing left in well:		Cement/Bentonite placed in well:		
From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

10) Surface Completion

Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

14) Typepump

Turbine Jet Submersible Cylinder
 Other _____

Depth to pump bowls, cylinder, jet, etc., _____ ft.

15) Water Test

Typetest Pump Bailer Jetted Estimated
 Yield: **20** gpm with _____ ft. drawdown after _____ hrs.

11) Water Level

Static level **65** ft. below Date **11/10/2000**
 Artesian Flow _____ gpm. Date **/ /**

16) Water Quality

Did you knowingly penetrate any strata which contain undesirable constituents?
 NO If yes, did you submit a REPORT OF UNDESIRABLE WATER?
 Type of water **GOOD** Depth of Strata _____
 Was a chemical analysis made? Yes No

12) Packers

Type	Depth
RUBBER	35

Company or Individual's Name (type or print) **SMART DRILLING & SUPPLY CO. INC.** Lic. No. **1814WI**

Address **HC 3 BOX 11** City **LAMPASAS** State **TX** Zip **76550**

Signature <i>Rest P. Sharp</i> Licensed Driller/Pump Installer	11/10/2000 Date	Signature _____ Apprentice	/ / Date
---	---------------------------	-------------------------------	-------------

From: Rachael Phillips <rachael@middletrinitygcd.org>
Sent: Thursday, December 14, 2023 4:09 PM
To: cburks@burksrealestate.com
Subject: Well ID: 4642

Unfortunately, there wasn't a lot of information for this one.
Depth - 342
Casing - 5"
GPM - 5
Pump Type – Submersible

If we can help with anything else please let us know.

Rachael Phillips

OFFICE ADMINISTRATOR

930 Wolfe Nursery Road,
Stephenville, TX 76401
O (254)965-6705
F (254)965-6745
rachael@middletrinitygcd.org
middletrinitygcd.org



Water Well No. 2

District ID	4643
Well Owner	Sam Golden
Well Operator	
Land Owner	
TWDB SWN	
State Grid Cell	40-41-6
Well Name	Well #2
Exempt	Yes
Monitored	No
Well Type	
Well Status	Active
Driller	
PumpInstaller	
Plugging	
Aquifer	Trinity
County	Coryell
Primary Use	Livestock Watering
Latitude (dd)	31.299015
Longitude (dd)	-97.888755
Elevation (ft)	
Elevation Source	
Coordinate Source	Geocode
Well Address	10240 FM 116, Gatesville, TX, 76528
Parcel ID	
Property Area (ac)	0.00
Distance to Nearest Property Line (ft)	
Well Depth (ft)	342
Casing Diameter (in)	5.00 inches
Pump Depth (ft)	
Production Rate (gpm)	5 GPM
Production Rate Equipped (gpm)	
MeterId	
Pump Size (hp)	0.00
Application Date	5/21/2011
Drilling Start Date	
Drilling Completion Date	
Legacy ID	1242CO
Application Type	
Max. Capacity (gpm)	
Casing Height (ft)	
State Well Report	

PumpType	Submersible
Completion Static Level (ft)	
Pump Capacity (gpm)	20.00
Plugging Date	
Construction Notes	
Plugging Report	